

Bergen ASCS : 30 Madonna Place Garfield
 Sample Date: March 25, 2017



Environmental and Laboratory Services
 90 1/2 West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: April 10, 2017
 Client: iLearn Schools, Inc.
 Address: 465 Boulevard
 Elmwood Park, NJ 07407

Project: Bergen Arts & Science Charter Elementary School (Grades K-3)

Sample description: Drinking Water / 1st Draw / DWS5040-1
 Sample location: Field Blank
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:04
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	22:17	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-2
 Sample location: #1 POE: Boiler Room (BES-POE-BR)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	30.2 µg/L	15 µg/L	03/31/17	16:55	2	4 µg/L

Sample description: Drinking Water / Flushed / DWS5040-2A
 Sample location: #1 POE: Boiler Room (BES-POE-BR)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 13:11
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	5 µg/L	04/03/17	17:58	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-3
 Sample location: #2 Sink Nurse Room (BES-GF-NS)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.81 µg/L	15 µg/L	03/30/17	22:22	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-4
 Sample location: #3 Room 106
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	22:28	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-5
 Sample location: #4 Sink Kitchen (BES-GF-KC-1)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:18
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	22:34	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-6
 Sample location: #5 Kitchen (BES-GF-KC-2)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.12 µg/L	15 µg/L	03/30/17	22:39	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-7
 Sample location: #6 Sink Kitchen (BES-GF-KC-3)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:23
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.35 µg/L	15 µg/L	03/30/17	22:52	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-8
 Sample location: #7 Sink Kitchen (BES-GF-FP-4)
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.68 µg/L	15 µg/L	03/30/17	22:58	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-9
 Sample location: #8 Hallway Fountain 2nd Fl
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:51
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	23:04	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-10
 Sample location: #10 Fountain by Boiler Room
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:13
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	23:10	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5040-11
 Sample location: #11 Fountain by Payphone
 Sampled by: D. Diaz
 Sample date: 03/25/17
 Time: 12:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/30/17	23:16	1	2 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

April 10, 2017
 Date