



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 11, 2017

Client: iLearn Schools, Inc.
Address: 465 Boulevard
Elmwood Park, NJ 07407

Project: Passaic Arts & Science Charter Intermediate School (Levels 3-5)

Sample description: Drinking Water / 1st Draw / DWS5160-1
Sample location: Field Blank
Sampled by: D. Diaz / D. Mitchell
Sample date: 04/08/17
Time: 06:09
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	00:30	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-2
Sample location: POE: Boiler Room
Sampled by: D. Diaz / D. Mitchell
Sample date: 04/08/17
Time: 06:11
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5,191 µg/L	15 µg/L	04/26/17	05:11	1,000	2,000 µg/L

Sample description: Drinking Water / Flushed / DWS5160-2A
Sample location: POE: Boiler Room
Sampled by: D. Diaz / D. Mitchell
Sample date: 04/08/17
Time: 07:25
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	10.0 µg/L	5 µg/L	05/04/17	17:30	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-3
Sample location: WC Janitor Closet (1F-JC-2)
Sampled by: D. Diaz / D. Mitchell
Sample date: 04/08/17
Time: 06:13
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	00:36	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-4
 Sample location: KC Kitchen-1 (1F-Kit-1)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	00:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-5
 Sample location: KC Kitchen-2 (1F-Kit-2)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:23
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	00:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-6
 Sample location: WC Room 204 (2F-204)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:39
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	01:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-7
 Sample location: WC Room 301 (3F-301)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 07:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	01:07	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-8
 Sample location: TL Teacher's Lounge (3F-TL)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 07:07
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.20 µg/L	15 µg/L	04/14/17	01:13	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-9
 Sample location: FP Kitchen-3 (1F-Kit-3) Right
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/14/17	01:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-10
 Sample location: DW Room 210 (2F-210-1) Bubblers
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.61 µg/L	15 µg/L	04/14/17	01:26	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-11
 Sample location: DW Room 210-2 (2F-210-2)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.93 µg/L	15 µg/L	04/14/17	01:32	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5160-12
 Sample location: HW Nurses Room 311 (3F-311)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 06:59
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	25.6 µg/L	15 µg/L	04/21/17	21:55	2	4.00 µg/L

Sample description: Drinking Water / Flushed / DWS5160-12A
 Sample location: HW Nurses Room 311 (3F-311)
 Sampled by: D. Diaz / D. Mitchell
 Sample date: 04/08/17
 Time: 07:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	5 µg/L	04/28/17	21:27	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

May 11, 2017
 Date