



Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 11, 2017
Client: iLearn Schools, Inc.
Address: 465 Boulevard
Elmwood Park, NJ 07407

Project: Paterson Arts & Science Charter School (Grades K-8)

Sample description: Drinking Water / 1st Draw / DWS5084-1
Sample location: Field Blank
Sampled by: D. Diaz
Sample date: 04/01/17
Time: 09:36
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	19:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-2
Sample location: POE- DW: Room 103A (1F-103A)
Sampled by: D. Diaz
Sample date: 04/01/17
Time: 09:37
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.46 µg/L	15 µg/L	05/03/17	19:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-3
Sample location: DW: Room 113A (1F-113A)
Sampled by: D. Diaz
Sample date: 04/01/17
Time: 09:45
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.43 µg/L	15 µg/L	05/03/17	19:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-4
Sample location: DW: Girls (1F-GR)
Sampled by: D. Diaz
Sample date: 04/01/17
Time: 09:49
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead (*)	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	19:54	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-5
 Sample location: DW: Boys (1F-MR)
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 09:48
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	19:59	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-6
 Sample location: CT: Cafeteria (1F-Café)
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 11:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.50 µg/L	15 µg/L	05/03/17	20:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-7
 Sample location: KC: Kitchen-1 (1F-Kit-1)
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 11:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.39 µg/L	15 µg/L	05/03/17	20:15	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-8
 Sample location: KC: Kitchen-2 (1F-Kit-2)
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 11:29
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.57 µg/L	15 µg/L	05/03/17	20:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-9
 Sample location: WC: Hall 1 (2F-Hall-1) Boys
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 09:58
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	20:26	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-10
 Sample location: DW: Room 207 (2F-207)
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 10:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	12.1 µg/L	15 µg/L	05/03/17	20:32	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-11
 Sample location: WC: Hall-2 (3F-Hall-2) Boys
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 10:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	20:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-12
 Sample location: WC#1 3rd Floor Girls Hall-1
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 11:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	20:43	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5084-13
 Sample location: WC#2 3rd Floor Girls Hall-1
 Sampled by: D. Diaz
 Sample date: 04/01/17
 Time: 11:02
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/03/17	20:49	1	2.00 µg/L

µg/L = micrograms per liter

Field Notes:

(*) DW: Girls (1F-GR) – Low Pressure

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

May 11, 2017
 Date